

**TEXAS COMMISSION ON JAIL STANDARDS
JAIL INSPECTION REPORT**

Facility Name: Crockett Co. Jail

Date: December 14, 2018

Item	Section	Paragraph	
1	261	.257	Plumbing work shall meet the requirements of the Southern Standard Building Code, or equivalent. Warm and cold water should be provided at all lavatories and warm water shall be provided at all showers. Warm water temperature shall be between 100 and 120 degrees Fahrenheit. All plumbing in inmate occupied areas should have quick shut off capability. During the walk-through of the facility, it was determined there was no hot water in the inmate living areas as required by minimum jail standards.
2	263	.42	The facility shall be inspected annually by a local fire official. The last Fire Marshal inspection was conducted on 8/28/2017 which places the inspection 4 months past due.



Jason Jouett-TCJS Inspector