

**TEXAS COMMISSION ON JAIL STANDARDS
JAIL INSPECTION REPORT**

Facility Name: Madison County Jail

Date: November 28, 2012

Item	Section	Paragraph	Comments
1	259	0.156	Power Operated Locks. Power operated locks shall be motor, solenoid, or pneumatic type and provide electrical control unlocking, key unlocking by manual operation, and automatic mechanical deadlocking of doors upon closing. A door position switch and door position indicator shall be provided for all doors equipped with power operated locks. Heavy-duty, detention type door closers should be provided on all swinging doors equipped with power operated locks.

The locks to all the cell doors, with the exception of Separation Cell B, cannot be operated electronically.

2	279	0.3	Facility Maintenance. Preventive maintenance, to include necessary repairs, shall be conducted to ensure a safe, secure, and sanitary facility.
---	-----	-----	---

During the walk-through, the inspector observed apparent evidence of water leaking from the roof in the following areas: the kitchen, the multi-purpose room and the middle hallway of the jail.



Fred St. Amant-T.C.J.S. Inspector