

**TEXAS COMMISSION ON JAIL STANDARDS**

**Facility Name:** Presidio County Jail      **JAIL INSPECTION REPORT Date:** November 13, 2012

Item	Section	Paragraph	Comments
1	263	.41	<p>Training and Drills. Training of staff for emergency situations shall be provided immediately upon employment and no less than each calendar quarter for all jail personnel to include fire, emergency, evacuation drills, and location and use of equipment.</p> <p><b>On day of inspection, documentation could not be provided to show that all jailers are receiving life safety training. No jailer, working in the control room has received any life safety training for the first 3 quarters of 2012.</b></p>
2	263	.42	<p>Fire Prevention Plan. Each facility, after consultation with the local fire department or Texas Commission on Fire Protection, shall have and implement a written plan, approved by the Commission, for fire prevention and a fire hazard inspection checklist which shall be evaluated no less than each calendar quarter. The facility shall be inspected annually by a local fire official.</p> <p><b>On day of inspection, documentation could not be provided to show that the Presidio County Jail has been inspected by a licensed fire marshal since 10/17/2011.</b></p>
3	263	.54	<p>Equipment. All life safety equipment shall be out of reach of inmates or otherwise secured from unauthorized tampering. At least 1 self-contained breathing apparatus shall be available and maintained in or near each facility control station. All staff shall be trained and quarterly drills conducted in the use of this equipment. A minimum of 1 unit shall be provided for each building of a multibuilding facility and on each floor of a multistory facility.</p> <p><b>On day of inspection, documentation could not be provided to show that all jailers are receiving S.C.B.A. training. No jailer, working in the control room has received any S.C.B.A. training for the first 3 quarters of 2012.</b></p>
4	263	.55	<p>Inspections, Maintenance, Testing. All life safety equipment shall be inspected, maintained, and tested by persons qualified to do so (whether under vendor contract, by state or private agency or otherwise) in order that such equipment shall be safe, secure, and fully operative at all times.</p> <p><b>On the day of inspection, documentation could not be provided to show that the Fire Control Panel has been inspected since 9/26/2011.</b></p>
5	275	.2	<p>Corrections Officer Training and Licensing. Personnel employed or appointed as jailers or guards of county jails shall be licensed as per the requirements of the Texas Commission on Law Enforcement Officer Standards and Education under the provisions of the Texas Administrative Code, Title 37. Personnel employed or appointed as jailers or guards at facilities operated under vendor contract with a county or city shall be subject to the same qualifications, training, and testing procedures as county jailers.</p> <p><b>On day of inspection, it was determined that at least 1 jailer (Allen, Samantha) does not have at least a valid Temporary Jailer's License. Temporary Jailer's license expired November 7, 2012.</b></p>
6	279	.1(2)	<p>Water and sewage systems not part of a city system and food preparation areas shall be inspected at least annually by health authorities and record kept for each inspection;</p> <p><b>On day of inspection, documentation could not be provided to show that the Presidio County Jail has received a health inspection since 8/24/2011.</b></p>

  
**Jimmy Barton, TCJS Inspector**