

**TEXAS COMMISSION ON JAIL STANDARDS  
JAIL INSPECTION REPORT**

Facility Name: Hunt County Jail

Date:

January 6-7, 2020

Item	Section	Paragraph	Comments
1	257	.9	<p>The facility shall conform to the building, safety, and health requirements of state and local authority.</p> <p><b>The generator at the annex was identified as having load transfer time greater than the 10 seconds allowed by NFPA Code 110. Transfer time was 21 seconds.</b></p>
2	279	.1(1)	<p>A regular daily schedule for the work and inspections necessary to keep the facility clean; which schedule shall be assigned and supervised by corrections officers who have the responsibility for keeping the facility clean and making regular sanitation inspections;</p> <p><b>The showers throughout the main jail were observed to have exposed concrete, fruit flies and an unknown black substance on the walls. The shower sanitation issues were a deficiency on the 2018 and 2019 annual inspections. The inspection team also observed sanitation issues in the kitchen including unresolved areas identified from the 2019 Health Inspection Report.</b></p>
3	279	.3	<p>Preventive maintenance, to include necessary repairs, shall be conducted to ensure a safe, secure, and sanitary facility.</p> <p><b>The main jail was identified to have false secure door indicators on the control board, numerous lights out throughout the facility and several exposed wall joint gaps throughout the facility.</b></p>



Jon Luna, TCJS Inspector



William Phariss, TCJS Inspector