

**TEXAS COMMISSION ON JAIL STANDARDS
JAIL INSPECTION REPORT**


Facility Name: Terrell County Jail

Date:

September 9, 2020

Item	Section	Paragraph	Comments
1	259	.157	Remote Controls. Doors to single cells, multiple occupancy cells, dormitories, and day rooms shall be capable of being locked and unlocked individually by control means located remote from the cell area.

The cell doors do not operate as designed. The cell doors cannot be locked or unlocked from a remote location as required by minimum jail standards.



Jennifer Shumake, TCJS Inspector