

TEXAS COMMISSION ON JAIL STANDARDS
JAIL INSPECTION REPORT

Facility Name: Erath County

Date:

April 12, 2021

| Item | Section | Paragraph | Comments |
|------|---------|-----------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | 263 | 0.55 | Inspections, Maintenance, Testing. All life safety equipment shall be inspected, maintained, and tested by persons qualified to do so (whether under vendor contract, by state or private agency or otherwise) in order that such equipment shall be safe, secure, and fully operative at all times. |

On the day of inspection, the facility fire panel was showing trouble in the system. The trouble code was related to a broken pipe in the facility sprinkler system that occurred in February 2021. Repairs had not been initiated as of the date of inspection.

RECEIVED

APR 15 2021

Texas Commission On
Jail Standards



Michael Gravitt, T.C.J.S. Inspector