

**XAS COMMISSION ON JAIL STANDARDS
JAIL INSPECTION REPORT**

Facility Name: Gaines County Jail

Date:

June 2, 2021

Item	Section	Paragraph	Comments
1	263	.56	Testing Emergency Power Equipment. Emergency power equipment shall be tested at least once each week and the electric load transferred to the circuits at least monthly. A load test was not conducted on the emergency generator 5 of the last 12 months.
2	265	.13(a)	Verify Veteran Status. (a) Each sheriff/operator shall investigate and verify the veteran status of each prisoner by using data made available from the Veterans Reentry Search Service (VRSS) operated by the United States Department of Veteran Affairs or similar service. (b) Each sheriff/ operator shall provide assistance to prisoners identified as veterans, Jail staff did not verify the veteran status of each inmate booked into the facility for 6 months.

Jason Jouett, TCJS Inspector



RECEIVED
JUN 10 2021
**Texas Commission On
Jail Standards**