

**(AS COMMISSION ON JAIL STANDARDS
JAIL INSPECTION REPORT**

Facility Name: Childress Co. Jail

Date:

June 21-22, 2021

Item	Section	Paragraph	Comments
1	263	.41	Training and Drills. Training of staff for emergency situations shall be provided immediately upon employment and no less than each calendar quarter for all jail personnel to include fire, emergency, evacuation drills, and location and use of equipment. Life safety training was not conducted during the past 12 months.
2	263	.42	Fire Prevention Plan. Each facility, after consultation with the local fire department or Texas Commission on Fire Protection, shall have and implement a written plan, approved by the Commission, for fire prevention and a fire hazard inspection checklist which shall be evaluated no less than each calendar quarter. Quarterly fire prevention checklist was not completed during the last 12 months.
3	263	.56	Testing Emergency Power Equipment. Emergency power equipment shall be tested at least once each week and the electric load transferred to the circuits at least monthly. A load test was not performed on the emergency generator during 4 of the last 12 months.



Jason Jouett, TCJS Inspector

RECEIVED

JUN 23 2021

**Texas Commission On
Jail Standards**