

**TEXAS COMMISSION ON JAIL STANDARDS
JAIL INSPECTION REPORT**

Facility Name: Hudspeth County Jail

Date:


January 19, 2022

Item	Section	Paragraph	Comments
1	259	.167	Two-way voice communication shall be available at all times between inmates and corrections officers. Intercoms in A tank, D tank and the Holding Cell do not work as designed. There was no two-way voice communication in these areas.
2	279	.1	Each facility shall have and implement a written plan, reviewed and approved by the commission, for the maintenance of an acceptable level of cleanliness and sanitation throughout the facility. During the walk-through of the jail, it was observed that the maintenance and sanitation of the jail does not meet the acceptable level of cleanliness and sanitation as required by minimum jail standards.

RECEIVED

JAN 23 2022

TEXAS COMMISSION
ON JAIL STANDARDS



**Earnestine Sanders
Inspector, TCJS**