

TEXAS COMMISSION ON JAIL STANDARDS
JAIL INSPECTION REPORT

Facility Name: Jim Hogg County Jail

Date:

January 4, 2023

Item	Section	Paragraph	Comments
1	263	.56	<p>Emergency power equipment shall be tested at least each week and the electric load transferred to the circuits at least monthly.</p> <p>Review of the generator log revealed that only one load test had been documented since June 2022.</p>
2	275	.4	<p>Inmates shall be supervised by an adequate number of jailers to comply with state law and this chapter. One jailer shall be provided on each floor of the facility where 10 or more inmates are housed, with no less than 1 jailer per 48 inmates or increments thereof on each floor for direct inmate supervision.</p> <p>Staffing records revealed that only one officer was provided for direct inmate supervision on the night shift. The facilities average daily population since September 2022 has been greater than 48 inmates.</p>

RECEIVED
JAN 10 2023

TEXAS COMMISSION
ON JAIL STANDARDS