

TEX. COMMISSION ON JAIL STANDARDS
JAIL RE-INSPECTION REPORT

Facility Name: Llano County Jail

Date: December 19, 2022

Item	Section	Paragraph	Comments
1	259	157	"Doors to single cells, multiple occupancy cells, dormitories, and day rooms shall be capable of being locked and unlocked individually by control means located remote from the cell area... All remote door controls shall be secure".

During the investigation of a complaint (Case ID: 30579) it was discovered that the Llano County Jail remote control of doors is inoperable and not expected to be operable for three months per the vendor.

2	275	1	..."There shall be two-way voice communication capability between inmates and jailers, licensed peace officers, bailiffs, and designated staff at all times. Closed circuit television may be used, but not in lieu of the required personal observation"...
---	-----	---	--

During the investigation of a complaint (Case ID: 30579) it was discovered that the intercom system at the Llano County Jail is inoperable and is not expected to be operable for three months per the vendor.

3	271	1(f)	Female inmates shall be separated by sight and sound from male inmates. When under direct, visual, and proximate supervision, males and females may simultaneously participate in work and program activities;
---	-----	------	--

During the investigation of a complaint (Case ID: 30579) it was discovered that a male and female inmate were allowed in person visits without direct, visual, and proximate supervision. These visits were intended to improve inmate behavior and not as participation in work or program activities.

R Morgan

Richard Morgan, TCJS Complaints Inspector

RECEIVED

DEC 20 2022

Texas Commission On
Jail Standards