

# TEXAS COMMISSION ON JAIL STANDARDS

EXECUTIVE DIRECTOR  
Brandon S. Wood



P.O. Box 12985  
Austin, Texas 78711  
Voice: (512) 463-5505  
Fax: (512) 463-3185  
<http://www.tcjs.state.tx.us>  
info@tcjs.state.tx.us

## NOTICE OF NON-COMPLIANCE CORYELL COUNTY JAIL

October 25, 2024

Please reference the Inspection Requirements Review and Jail Inspection Report issued on October 25, 2024, detailing the specific issues that resulted in the issuance of this notice of non-compliance.

Minimum Standards Violated:	Corrective Measure Required	Date Corrective Action Must Be Completed
263.56	Emergency power equipment shall be tested at least once each week and the electric load transferred to the circuits at least monthly. <b>Generator logs submitted for review failed to show that weekly tests of the facility generator were conducted as required. Records reviewed from April 2024 to October 2024 (26 weeks) show that 11 required weekly tests were not documented as being conducted.</b>	<b>Upon receipt of this notice.</b>

Judge Bill Stoudt, Longview, Chair  
Dr. Esmail Porsa, M.D., Parker, Vice-Chair  
Ross Reyes, Melissa

Sheriff Kelly Rowe, Lubbock  
Sheriff Raul "Pinky" Gonzales, Refugio  
Patricia M. Anthony, Garland

Commissioner Ben Perry, Waco  
Duane Lock, Southlake  
Monica McBride, Alpine

"The Commission on Jail Standards welcomes all suggestions and will promptly respond to all complaints directed against the agency or any facilities under its purview".

*To empower local government to provide safe, secure and suitable local jail facilities through proper rules and procedures while promoting innovative programs and ideas*