

TEXAS COMMISSION ON JAIL STANDARDS

EXECUTIVE DIRECTOR
Brandon S. Wood



P.O. Box 12985
Austin, Texas 78711
Voice: (512) 463-5505
Fax: (512) 463-3185
<http://www.tcjs.state.tx.us>
info@tcjs.state.tx.us

NOTICE OF NON-COMPLIANCE BROOKS COUNTY JAIL

May 27, 2025

Please reference the Inspection Requirements Review and Jail Inspection Report issued on May 21, 2025, detailing the specific issues that resulted in the issuance of this notice of non-compliance.

Minimum Standards Violated:	Corrective Measure Required	Date Corrective Action Must Be Completed
263.56	Emergency power equipment shall be tested at least once each week and the electric load transferred to the circuits at least monthly. Emergency power tests were not conducted from February 2025 thru May 2025. Jail Administration advised that these tests need to be conducted weekly (non-load) and monthly (load test).	Upon receipt of this notice.