

TEXAS COMMISSION ON JAIL STANDARDS

EXECUTIVE DIRECTOR
Brandon S. Wood



P.O. Box 12985
Austin, Texas 78711
Voice: (512) 463-5505
Fax: (512) 463-3185
<http://www.tcjs.state.tx.us>
info@tcjs.state.tx.us

NOTICE OF NON-COMPLIANCE POTTER COUNTY JAIL

May 23, 2025

Please reference the Inspection Requirements Review and Jail Inspection Report issued on May 20-22, 2025, detailing the specific issues that resulted in the issuance of this notice of non-compliance.

Minimum Standards Violated:	Corrective Measure Required	Date Corrective Action Must Be Completed
259.135	<p>Dormitories shall contain 9 to 48 bunks. Dormitories operated as direct supervision may accommodate more than 48 inmates but shall not exceed more than 72 inmates. Dormitories shall contain not less than 40 square feet of clear floor space for the first bunk plus 18 square feet of clear floor space for each additional bunk. Each dormitory shall have adequate toilets, lavatories, and may include showers. Dormitories with contiguous day rooms in direct supervision facilities may exceed 40% of the facility capacity.</p> <p>During the review of average daily population documentation for the last 12 months, it was determined the facility was above designed capacity in general population 101 days throughout the year, by 1 to 36 inmates</p>	Upon receipt of this notice.

Judge Bill Stoudt, Longview, Chair
Dr. Esmail Porsa, M.D., Parker, Vice-Chair
Ross Reyes, Melissa

Sheriff Kelly Rowe, Lubbock
Patricia M. Anthony, Garland

Commissioner Ben Perry, Waco
Duane Lock, Southlake
Monica McBride, Alpine

"The Commission on Jail Standards welcomes all suggestions and will promptly respond to all complaints directed against the agency or any facilities under its purview".

To empower local government to provide safe, secure and suitable local jail facilities through proper rules and procedures while promoting innovative programs and ideas