

# TEXAS COMMISSION ON JAIL STANDARDS

EXECUTIVE DIRECTOR  
Brandon S. Wood



P.O. Box 12985  
Austin, Texas 78711  
Voice: (512) 463-5505  
Fax: (512) 463-3185  
<http://www.tcjs.state.tx.us>  
[info@tcjs.state.tx.us](mailto:info@tcjs.state.tx.us)

## NOTICE OF NON-COMPLIANCE WILLACY COUNTY JAIL

February 3, 2026

Please reference the Inspection Requirements Review and Jail Inspection Report issued January 29, 2026, detailing the specific issues that resulted in the issuance of this notice of non-compliance.

Minimum Standards Violated:	Corrective Measure Required	Date Corrective Action Must Be Completed
263.31	Fire detection for inmate occupied areas shall be by means of listed and labeled smoke detectors. The detectors shall be so located to meet the smoke detection testing criterion of §263.51(f) of this title (relating to Smoke Management).	Upon receipt of this notice.

**Fire panel was inoperable at time of inspection.**

Judge Bill Stoudt, Longview, Chair  
Dr. Esmail Porsa, M.D., Parker, Vice-Chair  
Ross Reyes, Melissa

Sheriff Kelly Rowe, Lubbock  
Sheriff Raul "Pinky" Gonzales, Refugio  
Patricia M. Anthony, Garland

Commissioner Ben Perry, Waco  
Duane Lock, Southlake  
Monica McBride, Alpine

"The Commission on Jail Standards welcomes all suggestions and will promptly respond to all complaints directed against the agency or any facilities under its purview".  
*To empower local government to provide safe, secure and suitable local jail facilities through proper rules and procedures while promoting innovative programs and ideas*

# TEXAS COMMISSION ON JAIL STANDARDS

EXECUTIVE DIRECTOR  
Brandon S. Wood



P.O. Box 12985  
Austin, Texas 78711  
Voice: (512) 463-5505  
Fax: (512) 463-3185  
<http://www.tcjs.state.tx.us>  
[info@tcjs.state.tx.us](mailto:info@tcjs.state.tx.us)

## NOTICE OF NON-COMPLIANCE WILLACY COUNTY JAIL

February 3, 2026

Please reference the Inspection Requirements Review and Jail Inspection Report issued January 29, 2026, detailing the specific issues that resulted in the issuance of this notice of non-compliance.

Minimum Standards Violated:	Corrective Measure Required	Date Corrective Action Must Be Completed
263.31	Fire detection for inmate occupied areas shall be by means of listed and labeled smoke detectors. The detectors shall be so located to meet the smoke detection testing criterion of §263.51(f) of this title (relating to Smoke Management).	Upon receipt of this notice.

**Fire panel was inoperable at time of inspection.**

Judge Bill Stoudt, Longview, Chair  
Dr. Esmail Porsa, M.D., Parker, Vice-Chair  
Ross Reyes, Melissa

Sheriff Kelly Rowe, Lubbock  
Sheriff Raul "Pinky" Gonzales, Refugio  
Patricia M. Anthony, Garland

Commissioner Ben Perry, Waco  
Duane Lock, Southlake  
Monica McBride, Alpine

"The Commission on Jail Standards welcomes all suggestions and will promptly respond to all complaints directed against the agency or any facilities under its purview".  
*To empower local government to provide safe, secure and suitable local jail facilities through proper rules and procedures while promoting innovative programs and ideas*